Supplier	
	: Shell Eastern Trading (PTE) Ltd
	9 North Buona Vista Drive, #07-01, Tower 1, The Metropolis Singapore 138588 Singapore
Telephone Emergency Telephone Number	: +65-6384 8000 : +44 (0) 151 350 4595
AZARDS IDENTIFICATION	J
GHS Classification	<ul> <li>Flammable liquids, Category 1 Skin corrosion/irritation, Category 2 Aspiration hazard, Category 1 Toxic to reproduction, Category 2 Germ cell mutagenicity, Category 1B Carcinogenicity, Category 1B Specific target organ toxicity - single exposure, Category 3, Inhalation, Narcotic effects. Acute hazards to the aquatic environment, Category 2 Hazardous to the aquatic environment - Long-term Hazard, Category 2</li> </ul>
GHS Label Elements Symbol(s)	
Signal Words	: Danger
Hazard Statement	: PHYSICAL HAZARDS:

	H224: Extremely flammable liquid and vapour.
	HEALTH HAZARDS: H304: May be fatal if swallowed and enters airways. H315: Causes skin irritation. H336: May cause drowsiness or dizziness. H340: May cause genetic defects. H350: May cause cancer. H361: Suspected of damaging fertility or the unborn child.
	ENVIRONMENTAL HAZARDS: H401: Toxic to aquatic life. H411: Toxic to aquatic life with long lasting effects.
GHS Precautionary Statemer	
Prevention	<ul> <li>P201: Obtain special instructions before use.</li> <li>P210: Keep away from heat/sparks/open flames/hot surfaces No smoking.</li> <li>P280: Wear protective gloves/protective clothing/eye protection/face protection.</li> </ul>
Response	: P301+P310: IF SWALLOWED: Immediately call a POISON CENTER or doctor/physician.
Storage	<ul> <li>P403+P233: Store in a well-ventilated place. Keep container tightly closed.</li> </ul>
Disposal:	<ul> <li>P501: Dispose of contents and container to appropriate waste site or reclaimer in accordance with local and national regulations.</li> </ul>
Other Hazards which do not result in classification	<ul> <li>Liquid evaporates quickly and can ignite leading to a flash fire, or an explosion in a confined space. This material is a static accumulator. Even with proper grounding and bonding, this material can still accumulate an electrostatic charge. If sufficient charge is allowed to accumulate, electrostatic discharge and ignition of flammable air-vapour mixtures can occur.</li> <li>Slightly irritating to respiratory system. This product contains benzene which may cause leukaemia (AML - acute myelogenous leukaemia). May cause MDS (Myelodysplastic Syndrome).</li> </ul>
Additional Information	: This product is intended for use in closed systems only.
Print Date 16 04 2014	2/22 0000003404

#### 3. COMPOSITION/INFORMATION ON INGREDIENTS

Mixture Description	: Complex mixture of hydrocarbons consisting of paraffins, cycloparaffins, aromatic and olefinic hydrocarbons with carbon numbers predominantly in the C4 to C12 range. Includes benzene at 0.1 - 5% v/v. Contains oxygenated hydrocarbons which may include methyl tertiary butyl ether (MTBE) and other ethers. May also contain several additives at <0.1% v/v each.
Synonyms	: MOGAS, ULG 95, 88 RON, 90 RON, 91 RON, 92 RON, 93 RON, 95 RON, 97 UNLD, 91 UNLD

#### **Classification of components according to GHS**

Chemical Identity	Synonyms	CAS	Hazard Class	Hazard	Conc.
			(category)	Statement	
Gasoline, low boiling point naphtha	Gasoline, low boiling point naphtha	86290-81-5	Flam. Liq., 1; Skin Corr., 2; Asp. Tox., 1; Muta., 1B; Carc., 1B; STOT SE, 3; Aquatic Chronic, 2; Aquatic Acute, 2; Repr., 2;	H224; H315; H304; H340; H350; H336; H411; H401; H361;	85.00 - 100.00 %
Ethyl tertiary butyl ether	Ethyl tertiary butyl ether	637-92-3	Flam. Liq., 2; STOT SE, 3; Asp. Tox., 2; Aquatic Acute, 3;	H225; H336; H305; H402;	0.00 - 15.00 %
Methyl tertiary butyl ether	Methyl tertiary butyl ether	1634-04-4	Flam. Liq., 2; Skin Corr., 3; Acute Tox., 5; Asp. Tox., 2;	H225; H316; H303; H305;	0.00 - 15.00 %
Tertiary amyl methyl ether	Tertiary amyl methyl ether	994-05-8	Flam. Liq., 2; Acute Tox., 4; STOT SE, 3;	H225; H302; H336;	0.00 - 15.00 %

Additional Information

: Contains Benzene, CAS # 71-43-2. Contains Toluene, CAS # 108-88-3. Contains Ethylbenzene, CAS # 100-41-4. Contains n-Hexane, CAS # 110-54-3. Contains Xylene (Mixed Isomers), CAS # 1330-20-7. Contains Cyclohexane, CAS# 110-82-7. Contains Cumene, CAS# 98-82-8 Contains Tri-methyl-benzene (all isomers), CAS# 25551-13-7.

Contains Naphthalene, CAS # 91-20-3.

The amount of oxygenated components is limited at 2.7 % m/m calculated as oxygen. Alcohols may be present at <0.1%v. Dyes and markers can be used to indicate tax status and prevent fraud. Refer to Ch 16 for full text of H phrases.

Refer to chapter 16 for full text of EC R-phrases.

4. FIRST-AID MEASURES	
Inhalation	: Remove to fresh air. If rapid recovery does not occur, transport to nearest medical facility for additional treatment.
Skin Contact	: Remove contaminated clothing. Immediately flush skin with large amounts of water for at least 15 minutes, and follow by washing with soap and water if available. If redness, swelling, pain and/or blisters occur, transport to the nearest medical facility for additional treatment. When using high pressure equipment, injection of product under the skin can occur. If high pressure injuries occur, the casualty should be sent immediately to a hospital. Do not wait for symptoms to develop.
Eye Contact	: Flush eyes with water while holding eyelids open. Rest eyes for 30 minutes. If redness, burning, blurred vision, or swelling persist transport to the nearest medical facility for additional treatment.
Ingestion	: If swallowed, do not induce vomiting: transport to nearest medical facility for additional treatment. If vomiting occurs spontaneously, keep head below hips to prevent aspiration. If any of the following delayed signs and symptoms appear within the next 6 hours, transport to the nearest medical facility: fever greater than 101° F (38.3°C), shortness of breath, chest congestion or continued coughing or wheezing.
Most Important Symptoms/Effects, Acute & Delayed	Skin irritation signs and symptoms may include a burning sensation, redness, or swelling. Eye irritation signs and symptoms may include a burning sensation and a temporary redness of the eye. If material enters lungs, signs and symptoms may include coughing, choking, wheezing, difficulty in breathing, chest congestion, shortness of breath, and/or fever. The onset of respiratory symptoms may be delayed for several hours after exposure. Breathing of high vapour concentrations may cause central nervous system (CNS) depression resulting in dizziness, light-headedness, headache, nausea and loss of coordination. Continued inhalation may result in unconsciousness and death. Auditory system effects may include temporary hearing loss and/or ringing in the ears.

Immediate medical attention, special treatment

: Treat symptomatically.

#### 5. FIRE-FIGHTING MEASURES

Clear fire area of all non-emergency personnel.

from Chemicals	Hazardous combustion products may include: A complex mixture of airborne solid and liquid particulates and gases (smoke). Carbon monoxide may be evolved if incomplete combustion occurs. Unidentified organic and inorganic compounds. The vapour is heavier than air, spreads along the ground and distant ignition is possible. Will float and can be reignited on surface water.
Suitable Extinguishing Media	<ul> <li>Foam, water spray or fog. Dry chemical powder, carbon dioxide, sand or earth may be used for small fires only.</li> </ul>
Unsuitable Extinguishing Media	<ul> <li>Do not use direct water jets on the burning product as they could cause a steam explosion and spread of the fire.</li> <li>Simultaneous use of foam and water on the same surface is to be avoided as water destroys the foam.</li> </ul>
Protective Equipment & Precautions for Fire Fighters	Proper protective equipment including chemical resistant gloves are to be worn; chemical resistant suit is indicated if large contact with spilled product is expected. Self-Contained Breathing Apparatus must be worn when approaching a fire in a confined space. Select fire fighter's clothing approved to relevant Standards (e.g. Europe: EN469).
Additional Advice	Keep adjacent containers cool by spraying with water. If possible remove containers from the danger zone. If the fire cannot be extinguished the only course of action is to evacuate immediately. Contain residual material at affected sites to prevent material from entering drains (sewers), ditches, and waterways.

#### 6. ACCIDENTAL RELEASE MEASURES

Avoid contact with skin, eyes and clothing. Evacuate the area of all non-essential personnel. Ventilate contaminated area thoroughly. If contamination of sites occurs remediation may require specialist advice. Avoid contact with spilled or released material. Immediately remove all contaminated clothing. For guidance on selection of personal protective equipment see Chapter 8 of this Material Safety Data Sheet. For guidance on disposal of spilled material see Chapter 13 of this Material Safety Data Sheet. Ensure electrical continuity by bonding and grounding (earthing) all equipment. Observe the relevant local and international regulations. Take precautionary measures against static discharges.

Personal Precautions, Protective Equipment and Emergency Procedures	:	Do not breathe fumes, vapour. Do not operate electrical equipment. Shut off leaks, if possible without personal risks. Remove all possible sources of ignition in the surrounding area. Vapour can travel for considerable distances both above and below the ground surface. Underground services (drains, pipelines, cable ducts) can provide preferential flow paths. Evacuate all personnel. Attempt to disperse vapour or to direct its flow to a safe location for example using fog sprays.
Environmental Precautions	:	Take measures to minimise the effects on groundwater. Contain residual material at affected sites to prevent material from entering drains (sewers), ditches, and waterways. Prevent from spreading or entering into drains, ditches or rivers by using sand, earth, or other appropriate barriers.
Methods and Material for Containment and Cleaning Up	:	Take precautionary measures against static discharges. For large liquid spills (> 1 drum), transfer by mechanical means such as vacuum truck to a salvage tank for recovery or safe disposal. Do not flush away residues with water. Retain as contaminated waste. Allow residues to evaporate or soak up with an appropriate absorbent material and dispose of safely. Remove contaminated soil and dispose of safely. For small liquid spills (< 1 drum), transfer by mechanical means to a labelled, sealable container for product recovery or safe disposal. Allow residues to evaporate or soak up with an appropriate absorbent material and dispose of safely. Remove contaminated soil and dispose of safely. Remove
Additional Advice	:	Notify authorities if any exposure to the general public or the environment occurs or is likely to occur. Local authorities should be advised if significant spillages cannot be contained. Maritime spillages should be dealt with using a Shipboard Oil Pollution Emergency Plan (SOPEP), as required by MARPOL Annex 1 Regulation 26. To the extent that this product, including its chemical components (e.g. methyl tertiary butyl ether) may impact surface or groundwater, appropriate assessment and remediation (if necessary) should be implemented.
7. HANDLING AND STORAGE		
General Precautions	:	Avoid breathing vapours or contact with material. Only use in well ventilated areas. Wash thoroughly after handling. For guidance on selection of personal protective equipment see Chapter 8 of this Material Safety Data Sheet. Use the information in this data sheet as input to a risk assessment of local circumstances to help determine appropriate controls for

<ul> <li>Conditions for Safe Storage</li> <li>Drum and small container storage: Keep containers closed when not in use. Drums should be stacked to a maximum of 3 high. Use properly labelled and closeable containers. Packaged product must be kept tightly closed and stored in a diked (bunded) well-ventilated area, away from, ignition sources and other sources of heat. Take suitable precautions when opening sealed containers, as pressure can build up during storage. Tank storage: Tanks must be specifically designed for use with this product. Bulk storage tanks should be diked (bunded). Locate tanks away from heat and other sources of ignition. Cleaning, inspection and maintenance of storage tanks is a specialist operation, which requires the implementation of strict procedures and precautions. Keep in a cool place. Electrostatic charges will be generated during pumping. Electrostatic discharge may cause fire. Ensure electrical continuity by bonding and grounding (earthing) all equipment to reduce the risk. The vapours in the head space of the storage vessel may lie in the flammable/explosive range and hence may be flammable. Refer to section 15 for any additional specific legislation covering the packaging and storage of this product.</li> <li>Wait 2 minutes after tank filling (for tanks such as those on road tanker vehicles) before opening hatches or manholes. Wait 30 minutes after tank filling (for large storage tanks) before opening hatches or manholes. Even with proper grounding and bonding, this material can still accumulate an electrostatic charge. If sufficient charge is allowed to</li> </ul>	Precautions for Safe Handling	<ul> <li>safe handling, storage and disposal of this material. Air-dry contaminated clothing in a well-ventilated area before laundering. Prevent spillages. Turn off all battery operated portable electronic devices (examples include: cellular phones, pagers and CD players) before operating gasoline pump. Contaminated leather articles including shoes cannot be decontaminated and should be destroyed to prevent reuse. Do not use as a cleaning solvent or other non-motor fuel uses. Vehicle fueling and vehicle workshop areas - Avoid inhalation of vapours and contact with skin, when filling or emptying a vehicle.</li> <li>When using do not eat or drink. Extinguish any naked flames. Do not smoke. Remove ignition sources. Avoid sparks. Never siphon by mouth. The vapour is heavier than air, spreads along the ground and distant ignition is possible. Avoid exposure. Use local exhaust ventilation if there is risk of inhalation of vapours, mists or aerosols. Properly dispose of any contaminated rags or cleaning materials in order to prevent</li> </ul>
	Storage	<ul> <li>fires.</li> <li>Drum and small container storage: Keep containers closed when not in use. Drums should be stacked to a maximum of 3 high. Use properly labelled and closeable containers. Packaged product must be kept tightly closed and stored in a diked (bunded) well-ventilated area, away from, ignition sources and other sources of heat. Take suitable precautions when opening sealed containers, as pressure can build up during storage. Tank storage: Tanks must be specifically designed for use with this product. Bulk storage tanks should be diked (bunded). Locate tanks away from heat and other sources of ignition. Cleaning, inspection and maintenance of storage tanks is a specialist operation, which requires the implementation of strict procedures and precautions. Keep in a cool place. Electrostatic charges will be generated during pumping. Electrostatic discharge may cause fire. Ensure electrical continuity by bonding and grounding (earthing) all equipment to reduce the risk. The vapours in the head space of the storage vessel may lie in the flammable/explosive range and hence may be flammable. Refer to section 15 for any additional specific legislation covering the packaging and storage of this product.</li> <li>Wait 2 minutes after tank filling (for tanks such as those on road tanker vehicles) before opening hatches or manholes. Wait 30 minutes after tank filling (for large storage tanks) before opening hatches or manholes. Even with proper grounding and bonding, this material can still accumulate an</li> </ul>

	accumulate, electrostatic discharge and ignition of flammable air-vapour mixtures can occur. Be aware of handling operations that may give rise to additional hazards that result from the accumulation of static charges. These include but are not limited to pumping (especially turbulent flow), mixing, filtering, splash filling, cleaning and filling of tanks and containers, sampling, switch loading, gauging, vacuum truck operations, and mechanical movements. These activities may lead to static discharge e.g. spark formation. Restrict line velocity during pumping in order to avoid generation of electrostatic discharge (<= 1 m/s until fill pipe submerged to twice its diameter, then <= 7 m/s). Avoid splash filling. Do NOT use compressed air for filling, discharging, or handling operations.
Recommended Materials	: For containers, or container linings use mild steel, stainless steel. Aluminium may also be used for applications where it does not present an unnecessary fire hazard. Examples of suitable materials are: high density polyethylene (HDPE), polypropylene (PP), and Viton (FKM), which have been specifically tested for compatibility with this product. For container linings, use amine-adduct cured epoxy paint. For seals and gaskets use: graphite, PTFE, Viton A, Viton B.
Unsuitable Materials	: Some synthetic materials may be unsuitable for containers or container linings depending on the material specification and intended use. Examples of materials to avoid are: natural rubber (NR), nitrile rubber (NBR), ethylene propylene rubber (EPDM), polymethyl methacrylate (PMMA), polystyrene, polyvinyl chloride (PVC), polyisobutylene. However, some may be suitable for glove materials.
Container Advice	: Containers, even those that have been emptied, can contain explosive vapours. Do not cut, drill, grind, weld or perform similar operations on or near containers. Gasoline containers must not be used for storage of other products.
Other Advice	: Ensure that all local regulations regarding handling and storage facilities are followed. See additional references that provide safe handling practices for liquids that are determined to be static accumulators: American Petroleum Institute 2003 (Protection Against Ignitions Arising out of Static, Lightning and Stray Currents) or National Fire Protection Agency 77 (Recommended Practices on Static Electricity). CENELEC CLC/TR 50404 (Electrostatics – Code of practice for the avoidance of hazards due to static electricity).

#### 8. EXPOSURE CONTROLS/PERSONAL PROTECTION

If the American Conference of Governmental Industrial Hygienists (ACGIH) value is provided on this document, it is provided for information only.

Material	Source	Туре	ppm	mg/m3	Notation
Gasoline, low boiling point naphtha	ACGIH	TWA	300 ppm		
	ACGIH	STEL	500 ppm		
	SG OEL	TWA	300 ppm	890 mg/m3	
	SG OEL	STEL	500 ppm	1,480 mg/m3	
Trimethylbenzene , all isomers	ACGIH	TWA	25 ppm		
	SG OEL	TWA	25 ppm	123 mg/m3	
Ethylbenzene	ACGIH	TWA	20 ppm		
	SG OEL	TWA	100 ppm	434 mg/m3	
	SG OEL	STEL	125 ppm	543 mg/m3	
n-hexane	ACGIH	TWA	50 ppm		
	ACGIH	SKIN_DES			Can be absorbed through the skin.
	SG OEL	TWA	50 ppm	176 mg/m3	
Benzene	ACGIH	TWA	0.5 ppm		
	ACGIH	STEL	2.5 ppm		
	ACGIH	SKIN_DES			Can be absorbed through the skin.
	SG OEL	TWA	1 ppm	3.18 mg/m3	

#### Occupational Exposure Limits

Effective Date 10.03.2014

# Safety Data Sheet

	SHELL IS	TWA	0.5 ppm	1.6 mg/m3	
	SHELL IS	STEL	2.5 ppm	8 mg/m3	
Toluene	ACGIH	TWA	20 ppm		
	SG OEL	TWA	50 ppm	188 mg/m3	
Xylene	ACGIH	TWA	100 ppm		
	ACGIH	STEL	150 ppm		
	SG OEL	TWA	100 ppm	434 mg/m3	
	SG OEL	STEL	150 ppm	651 mg/m3	
Cyclohexane	ACGIH	TWA	100 ppm		
	SG OEL	TWA	300 ppm	1,030 mg/m3	
Naphthalene	ACGIH	TWA	10 ppm		
	ACGIH	STEL	15 ppm		
	ACGIH	SKIN_DES			Can be absorbed through the skin.
	SG OEL	TWA	10 ppm	52 mg/m3	
	SG OEL	STEL	15 ppm	79 mg/m3	
Ethyl tertiary butyl ether	ACGIH	TWA	25 ppm		
Methyl tertiary butyl ether	ACGIH	TWA	50 ppm		
	SG OEL	TWA	40 ppm	144 mg/m3	
Tertiary amyl methyl ether	ACGIH	TWA	20 ppm		
Cumene	ACGIH	TWA	50 ppm		
	SG OEL	TWA	50 ppm	246 mg/m3	

# Additional Information : SHELL IS is the Shell Internal Standard. Skin notation means that significant exposure can also occur by absorption of liquid through the skin and of vapour through the eyes or mucous membranes.

#### **Biological Exposure Index (BEI)**

Material	Determinant	Sampling Time	BEI	Reference
Benzene	t,t-Muconic acid in Creatinine in urine	Sampling time: End of shift.	500 µg/g	ACGIH BEL (2011)
	S- Phenylmercaptu ric acid in Creatinine in urine	Sampling time: End of shift.	25 µg/g	ACGIH BEL (2011)
n-hexane	2,5-Hexanedion, without hydrolysis in Urine	Sampling time: End of shift at end of work week.	0.4 mg/l	ACGIH BEL (2011)
Toluene	o-Cresol, with hydrolysis in Creatinine in urine	Sampling time: End of shift.	0.3 mg/g	ACGIH BEL (2011)
	toluene in Blood	Sampling time: Prior to last shift of work week.	0.02 mg/l	ACGIH BEL (2011)
	toluene in Urine	Sampling time: End of shift.	0.03 mg/l	ACGIH BEL (2011)

Effective Date 10.03.2014

#### Safety Data Sheet

Ethylbenzene	Sum of mandelic acid and phenylglyoxylic acid in Creatinine in urine	Sampling time: End of shift at end of work week.	0.7 g/g	ACGIH BEL (2011)
	Ethyl benzene in End-exhaled air	Sampling time: Not critical.		ACGIH BEL (2011)
Xylene	Methylhippuric acids in Creatinine in urine	Sampling time: End of shift.	1.5 g/g	ACGIH BEL (2011)
Naphthalene	1-Naphthol, with hydrolysis + 2- Naphthol, with hydrolysis	Sampling time: End of shift.		ACGIH BEL (02 2013)

**Appropriate Engineering** The level of protection and types of controls necessary will vary Controls depending upon potential exposure conditions. Select controls based on a risk assessment of local circumstances. Appropriate measures include: Use sealed systems as far as possible. Adequate explosion-proof ventilation to control airborne concentrations below the exposure guidelines/limits. Local exhaust ventilation is recommended. Eye washes and showers for emergency use. Always observe good personal hygiene measures, such as washing hands after handling the material and before eating, drinking, and/or smoking. Routinely wash work clothing and protective equipment to remove contaminants. Discard contaminated clothing and footwear that cannot be cleaned. Practice good housekeeping. Define procedures for safe handling and maintenance of controls. Educate and train workers in the hazards and control measures relevant to normal activities associated with this product. Ensure appropriate selection, testing and maintenance of equipment used to control exposure, e.g. personal protective equipment, local exhaust ventilation. Firewater monitors and deluge systems are recommended. Drain down system prior to equipment break-in or maintenance. Retain drain downs in sealed storage pending disposal or for subsequent recycle.

Individual Protection Measures	:	Personal protective equipment (PPE) should meet recommended national standards. Check with PPE suppliers.
Respiratory Protection	:	If engineering controls do not maintain airborne concentrations to a level which is adequate to protect worker health, select respiratory protection equipment suitable for the specific conditions of use and meeting relevant legislation. Check with respiratory protective equipment suppliers. Where air-filtering respirators are suitable, select an appropriate combination of mask and filter. Where air-filtering respirators are unsuitable (e.g. airborne concentrations are high, risk of oxygen deficiency, confined space) use appropriate positive pressure breathing apparatus. All respiratory protection equipment and use must be in accordance with local regulations. Select a filter suitable for combined particulate/organic gases and vapours [boiling point >65°C(149°F)]. Personal hygiene is a key element of effective hand care. Gloves must only be worn on clean hands. After using gloves, hands should be washed and dried thoroughly. Application of a non-perfumed moisturizer is recommended. Suitability and durability of a glove is dependent on usage, e.g. frequency and duration of contact, chemical resistance of glove material, dexterity. Always seek advice from glove suppliers. Contaminated gloves should be replaced. For continuous contact we recommend gloves with breakthrough time of more than 240 minutes with preference for > 480 minutes where suitable gloves can be identified. For short-term/splash protection we recommend the same, but recognise that suitable gloves offering this level of protection may not be available and in this case a lower breakthrough time may be acceptable so long as appropriate maintenance and replacement regimes are followed. Glove thickness is not a good predictor of glove resistance to a chemical as it is dependent on the exact composition of the glove material. Select gloves tested to a relevant standard (e.g. Europe EN374, US F739). When prolonged or frequent repeated contact occurs, Nitrile gloves may be suitable. (Breakthrough time of > 240 minutes.) For incidental contact/splash prot
Eye Protection	:	Chemical splash goggles (chemical monogoggles). If a local risk assessment deems it so, then chemical splash goggles may not be required and safety glasses may provide adequate
Protective Clothing	:	eye protection. Chemical resistant gloves/gauntlets, boots, and apron (where risk of splashing).
Thermal Hazards	:	Not applicable.
		13/22

Monitoring Methods :	Monitoring of the concentration of substances in the breathing zone of workers or in the general workplace may be required to confirm compliance with an OEL and adequacy of exposure controls. For some substances biological monitoring may also be appropriate. Validated exposure measurement methods should be applied by a competent person and samples analysed by an accredited laboratory. Examples of sources of recommended exposure measurement methods are given below or contact the supplier. Further national methods may be available.
Environmental Exposure : Controls	National Institute of Occupational Safety and Health (NIOSH), USA: Manual of Analytical Methods http://www.cdc.gov/niosh/ Occupational Safety and Health Administration (OSHA), USA: Sampling and Analytical Methods http://www.osha.gov/ Local guidelines on emission limits for volatile substances must be observed for the discharge of exhaust air containing vapour. Take appropriate measures to fulfil the requirements of relevant environmental protection legislation. Avoid contamination of the environment by following advice given in Chapter 6. If necessary, prevent undissolved material from being discharged to waste water. Waste water should be treated in a municipal or industrial waste water treatment plant before discharge to surface water.

#### 9. PHYSICAL AND CHEMICAL PROPERTIES

Appearance Odour	:Yellow. Clear, bright liquid. :Hydrocarbon
Odour threshold	: Data not available
pH	: Data not available
Initial Boiling Point and	: 25 - 220 °C / 77 - 428 °F
Boiling Range	
Freezing Point	: Data not available
Flash point	: -40 °C / -40 °F (Tagliabue Closed Cup)
Upper / Iower	: 1 - 8 %(V)
Flammability or	
Explosion limits	
Auto-ignition temperature	:>250 °C / 482 °F
Vapour pressure	: Typical 570 hPa at 37.8 °C / 100.0 °F
Relative Density	: Data not available
Density	: Typical 0.740 g/cm3 at 15 °C / 59 °F
Water solubility	: Negligible.
Solubility in other	: Data not available
solvents	

n-octanol/water partition : 2-7

14/22

00000034041 MSDS\_SG

coefficient (log Pow)	
Dynamic viscosity	: Data not available
Kinematic viscosity	: 0.5 - 0.75 mm2/s at 40 °C / 104 °F
Vapour density (air=1)	: Data not available
Electrical conductivity	: Low conductivity: < 100 pS/m, The conductivity of this material makes it a static accumulator., A liquid is typically considered nonconductive if its conductivity is below 100 pS/m and is considered semi-conductive if its conductivity is below 10 000 pS/m., Whether a liquid is nonconductive or semi-conductive, the precautions are the same., A number of factors, for example liquid temperature, presence of contaminants, and anti-static additives can greatly influence the conductivity of a liquid.
Evaporation rate (nBuAc=1)	: Data not available
Decomposition Temperature	: Data not available
Flammability	: Extremely flammable.

#### 10. STABILITY AND REACTIVITY

Chemical stability Possibility of Hazardous Reactions Conditions to Avoid Incompatible Materials Hazardous Decomposition Products	<ul> <li>Stable under normal conditions of use.</li> <li>No hazardous reaction is expected when handled and stored according to provisions.</li> <li>Avoid heat, sparks, open flames and other ignition sources.</li> <li>Strong oxidising agents.</li> <li>Hazardous decomposition products are not expected to form during normal storage. Thermal decomposition is highly dependent on conditions. A complex mixture of airborne solids, liquids and gases, including carbon monoxide, carbon dioxide and other organic compounds will be evolved when this material undergoes combustion or thermal or oxidative degradation.</li> <li>No</li> </ul>
Hazardous Polymerisation Sensitivity to Mechanical Impact Sensitivity to Static Discharge	<ul> <li>No</li> <li>Yes, in certain circumstances product can ignite due to static electricity.</li> </ul>

#### 11. TOXICOLOGICAL INFORMATION

# Information on Toxicological effects

Basis for Assessment	:	Information given is based on product data, a knowledge of the components and the toxicology of similar products. Unless indicated otherwise, the data presented is representative of the
		15/22

Likely Routesof Exposure Acute Oral Toxicity	:	product as a whole, rather than for individual component(s). Exposure may occur via inhalation, ingestion, skin absorption, skin or eye contact, and accidental ingestion. Low toxicity: LD50 > 5000 mg/kg
Acute Dermal Toxicity	:	Low toxicity: LD50 >2000 mg/kg , Rabbit
Acute Inhalation Toxicity	:	Low toxicity: LC50 >5 mg/l , 4 h, Rat
Skin corrosion/irritation	:	Irritating to skin.
Serious eye	:	Expected to be slightly irritating.
damage/irritation Respiratory Irritation	:	Based on human experience, breathing of vapours or mists may cause a temporary burning sensation to nose, throat and lungs.
Respiratory or skin sensitisation	:	Not expected to be a sensitiser.
Aspiration Hazard	:	Aspiration into the lungs when swallowed or vomited may cause chemical pneumonitis which can be fatal.
Germ cell mutagenicity	:	May cause heritable genetic damage. (Benzene) Mutagenicity studies on gasoline and gasoline blending streams have shown predominantly negative results.
Carcinogenicity	:	Known human carcinogen. (Benzene) May cause leukaemia (AML - acute myelogenous leukemia). (Benzene) Inhalation exposure to mice causes liver tumours, which are not considered relevant to humans.

Material	:	Carcinogenicity Classification
Gasoline, low boiling point naphtha	:	ACGIH Group A3: Confirmed animal carcinogen with unknown relevance to humans.
Gasoline, low boiling point naphtha	:	IARC 2B: Possibly carcinogenic to humans.
Gasoline, low boiling point naphtha	:	GHS / CLP: Carcinogenicity Category 1B
Trimethylbenzene, all isomers	:	GHS / CLP: No carcinogenicity classification
Ethylbenzene	:	IARC 2B: Possibly carcinogenic to humans.
Ethylbenzene	:	GHS / CLP: No carcinogenicity classification
n-hexane	:	GHS / CLP: No carcinogenicity classification

Benzene	:	ACGIH Group A1: Confirmed human carcinogen.
Benzene	:	NTP: Known To Be Human Carcinogen.
Benzene	:	IARC 1: Carcinogenic to humans.
Benzene	:	GHS / CLP: Carcinogenicity Category 1A
Toluene	:	ACGIH Group A4: Not classifiable as a human carcinogen.
Toluene	:	IARC 3: Not classifiable as to carcinogenicity to humans.
Toluene	:	GHS / CLP: No carcinogenicity classification
Xylene	:	ACGIH Group A4: Not classifiable as a human carcinogen.
Xylene	:	IARC 3: Not classifiable as to carcinogenicity to humans.
Xylene	:	GHS / CLP: No carcinogenicity classification
Cyclohexane	:	GHS / CLP: No carcinogenicity classification
Naphthalene	:	ACGIH Group A4: Not classifiable as a human carcinogen.
Naphthalene	:	NTP: Reasonably Anticipated to be a Human Carcinogen.
Naphthalene	:	IARC 2B: Possibly carcinogenic to humans.
Naphthalene	:	GHS / CLP: Carcinogenicity Category 2
Ethyl tertiary butyl ether	:	ACGIH Group A4: Not classifiable as a human carcinogen.
Ethyl tertiary butyl ether	:	GHS / CLP: No carcinogenicity classification
Methyl tertiary butyl ether	:	IARC 3: Not classifiable as to carcinogenicity to humans.
Methyl tertiary butyl ether	:	GHS / CLP: No carcinogenicity classification
Tertiary amyl methyl ether	:	GHS / CLP: No carcinogenicity classification
Cumene	:	IARC 2B: Possibly carcinogenic to humans.
Cumene	:	GHS / CLP: No carcinogenicity classification

Reproductive and Developmental Toxicity	<ul> <li>Causes foetotoxicity at doses which are maternally toxic. (Toluene) May impair fertility at doses which produce other toxic effects. (n-hexane) Many case studies involving abuse during pregnancy indicate that toluene can cause birth defects, growth retardation and learning difficulties. (Toluene) Inhalation of high concentrations of gasoline vapour containing Methyl tertiary butyl ether produced a very low incidence of rare birth defects (ventral midline closure failure) in mice.</li> </ul>
Specific target organ toxicity - single exposure	: High concentrations may cause central nervous system depression resulting in headaches, dizziness and nausea; continued inhalation may result in unconsciousness and/or death.
Specific target organ toxicity - repeated exposure	<ul> <li>Kidney: caused kidney effects in male rats which are not considered relevant to humans</li> <li>Blood-forming organs: repeated exposure affects the bone</li> </ul>
	17/22

# Additional Informationmarrow.Additional Information:Prolonged and repeated exposures to high concentrations<br/>have resulted in hearing loss in rats. Solvent abuse and noise<br/>interaction in the work environment may cause hearing loss.<br/>(Toluene)Abuse of vapours has been associated with organ damage and<br/>death. (Toluene)Exposure to very high concentrations of similar materials has<br/>been associated with irregular heart rhythms and cardiac<br/>arrest.May cause MDS (Myelodysplastic Syndrome). (Benzene)Classifications by other authorities under varying regulatory<br/>frameworks may exist.

#### 12. ECOLOGICAL INFORMATION

Basis for Assessment	:	Fuels are typically made from blending several refinery streams. Ecotoxicological studies have been carried out on a variety of hydrocarbon blends and streams but not those containing additives. Information given is based on a knowledge of the components and the ecotoxicology of similar products. Unless indicated otherwise, the data presented is representative of the product as a whole, rather than for individual component(s).
Acute Toxicity Fish Aquatic crustacea Algae/aquatic plants Microorganisms	:	Expected to be toxic: LL/EL/IL50 > 1 <= 10 mg/l (to aquatic organisms) LL/EL50 expressed as the nominal amount of product required to prepare aqueous test extract. Expected to be toxic: LL/EL/IL50 > 1 <= 10 mg/l Expected to be toxic: LL/EL/IL50 > 1 <= 10 mg/l Expected to be toxic: LL/EL/IL50 > 1 <= 10 mg/l Expected to be toxic: LL/EL/IL50 > 1 <= 10 mg/l
Chronic Toxicity Fish Aquatic crustacea Mobility	:	NOEC/NOEL expected to be > 1.0 - <= 10 mg/l NOEC/NOEL expected to be > 1.0 - <= 10 mg/l Evaporates within a day from water or soil surfaces. Large volumes may penetrate soil and could contaminate groundwater. Toxic to aquatic organisms; may cause long-term adverse effects in the aquatic environment. Ether oxygenates are significantly more water soluble and less biodegradable

Persistence/degradability	than benzene, toluene, ethyl benzene and xylenes (BTEX). Consequently ether oxygenates have the potential to migrate relatively longer distances than BTEX in groundwater. Contains volatile components. Floats on water. Methyl tertiary butyl ether degradation may result in the formation of tert-butyl alcohol (TBA). Major constituents are expected to be inherently
	biodegradable, but the product contains components that may persist in the environment. The volatile constituents will oxidize rapidly by photochemical reactions in air. While biodegradation of Methyl tertiary butyl ether has been documented, it is generally less biodegradable than many petroleum hydrocarbons and has a potential to migrate relatively longer distances in groundwater.
Bioaccumulative Potential	: Contains constituents with the potential to bioaccumulate. Log Kow > =4
Other Adverse Effects	<ul> <li>Films formed on water may affect oxygen transfer and damage organisms.</li> </ul>

#### 13. DISPOSAL CONSIDERATIONS

Material Disposal :	Recover or recycle if possible. It is the responsibility of the waste generator to determine the toxicity and physical properties of the material generated to determine the proper waste classification and disposal methods in compliance with applicable regulations. Waste arising from a spillage or tank cleaning should be disposed of in accordance with prevailing regulations, preferably to a recognised collector or contractor. The competence of the collector or contractor should be established beforehand. Do not dispose into the environment, in drains or in water courses. Do not dispose of tank water bottoms by allowing them to drain into the ground. This will result in soil and groundwater contamination.
Container Disposal :	Drain container thoroughly. After draining, vent in a safe place away from sparks and fire. Residues may cause an explosion hazard. Do not puncture, cut, or weld uncleaned drums. Send to drum recoverer or metal reclaimer. Do not pollute the soil, water or environment with the waste container.
Local Legislation :	Disposal should be in accordance with applicable regional, national, and local laws and regulations. Local regulations may be more stringent than regional or national requirements and must be in compliance.

#### 14. TRANSPORT INFORMATION

Land (as per ADR classific	ation): Regulated
Class	: 3
Packing group	: 11
Hazard indentification no.	: 33
UN number	: 1203
Danger label (primary risk)	
	: GASOLINE (UNLEADED)
Environmentally Hazardous	: Yes
IMDG	
Identification number	UN 1203
Proper shipping name	GASOLINE
Technical name	(UNLEADED)
Class / Division	3
Packing group	II
Environmental hazards:	Yes
IATA (Country variations n UN number Proper shipping name Technical name Class / Division Packing group	may apply) : 1203 : Gasoline : (UNLEADED) : 3 : II
Transport in bulk accordin	ig to Annex II of MARPOL 73/78 and the IBC Code
Pollution Category	: Not applicable.
Ship Type	: Not applicable.
Product Name	: Not applicable.
Special Precaution	: Not applicable.
Additional Information	: MARPOL Annex 1 rules apply for bulk shipments by sea.

#### 15. REGULATORY INFORMATION

The regulatory information is not intended to be comprehensive. Other regulations may apply to this material.

Local Regulations	
-------------------	--

Workplace Safety and Health Act & Workplace

: This product is subject to the requirement in the Act/ Regulations.

20/22

Print Date 16.04.2014

00000034041 MSDS\_SG

Effective Date 10.03.2014

	Safety and Health (General Provision) Regulations Environmental Protection and Management Act and Environmental Protection and Management (Hazardous Substances) Regulations Maritime and Port Authority of Singapore (Dangerous Goods, Petroleum and Explosives) Regulations Fire Safety Act and Fire Safety (Petroleum & Flammable Materials) Regulations		:	This product is subject to the requirement in the A Regulations.	.ct/	
				Regulations.		
			:	This product is subject to the requirement in the A Regulations.	.ct/	
			:	This product is subject to the requirement in the A Regulations.	.ct/	
	Classification t components	riggering	:	Contains gasoline, low boiling point naphtha, unsp	pecified.	
16.		ATION				
	Hazard Statem					
	H224	Extremely fla	amr	mable liquid and vapour.		
	H225			ole liquid and vapour.		
	H302	Harmful if swallowed.				
	H303	May be harmful if swallowed.				
	H304	May be fatal if swallowed and enters airways.				
	H305 May be harmful if swallowed and enters airways.					
	H315 Causes skin iri					
	H316 Causes mild			in irritation.		
	H336 May cause drowsiness or dizziness.					
	H340	May cause g				
	H350	May cause o				
	H361	Suspected of	of da	amaging fertility or the unborn child.		
	H401	Toxic to aqu				
	H402 Harmful to ad					
	H411	Toxic to aqu	atic	clife with long lasting effects.		
	Additional Info	ormation	:	This document contains important information to e safe storage, handling and use of this product. Th in this document should be brought to the attent person in your organisation responsible for advisi matters.	e information ion of the	
	SDS Version N	umber	:	1.0		
	SDS Effective	Date	:	10.03.2014		
				21/22		
Print	Date 16.04.201	4			00000034041	
					MSDS_SG	

# Effective Date 10.03.2014

SDS Revisions Uses and Restrictions	:	A vertical bar ( ) in the left margin indicates an amendment from the previous version. This product must not be used in applications other than those recommended in Section 1, without first seeking the advice of the supplier. This product is not to be used as a solvent or cleaning agent; for lighting or brightening fires; as a skin cleanser. This product is designed only to suit automotive applications and no provision is made for the requirements of aviation applications.		
SDS Distribution	:	The information in this document should be made available to all who may handle the product.		
Key/Legend to Abbrevations used in this SDS			The standard abbreviations and acronyms used in this document can be looked up in reference literature (e.g. scientific dictionaries) and/or websites.	
		Flam. Liq. Asp. Tox. Muta. Carc. Skin Corr. STOT SE	Flammable liquids Aspiration hazard Germ cell mutagenicity Carcinogenicity Skin corrosion/irritation Specific target organ toxicity - single exposure Toxic for Reproduction	
Key Literature References	:	The quoted data are from, but not limited to, one or more sources of information (e.g. toxicological data from Shell Health Services, material suppliers' data, CONCAWE, EU IUCLID date base, EC 1272 regulation, etc).		
Disclaimer	:	This information is based on our current knowledge and is intended to describe the product for the purposes of health, safety and environmental requirements only. It should not therefore be construed as guaranteeing any specific property of the product.		